

Design/System/Construction/Assembly Usage Disclaimer

- Authorities Having Jurisdiction should be consulted in all cases as to the particular requirements covering the installation and use of UL Certified products, equipment, system, devices, and materials.
- Authorities Having Jurisdiction should be consulted before construction.
- Fire resistance assemblies and products are developed by the design submitter and have been investigated by UL for compliance with applicable requirements. The published information cannot always address every construction nuance encountered in the field.
- When field issues arise, it is recommended the first contact for assistance be the technical service staff provided by the product manufacturer noted for the design. Users of fire resistance assemblies are advised to consult the general Guide Information for each product category and each group of assemblies. The Guide Information includes specifics concerning alternate materials and alternate methods of construction.
- Only products which bear UL's Mark are considered Certified.

Roof Deck Constructions


[See General Information for Roof Deck Constructions](#)

Construction No. 275

December 10, 1996

Wind Uplift — Class 90

Fire Not Investigated



1. **Metal Roof Deck Panels*** — No. 24 ga. MSG coated steel or 0.032 in. thick aluminum panels. The panels are 12 in. or 16 in. wide and 2-1/2 in. high at the ribs. Panels are continuous over two or more spans. Adjacent panels to be seamed with an electric seamer, with seaming operation to include panel clips (Item 2).

FABRAL INC ([View Classification](#)) — "Stand'N Seam"

2. **Roof Deck Fastener*** — (Panel Clips) — Clips fabricated from No. 18 MSG stainless steel consisting of a one piece assembly 3 in. wide where the upper portion is formed to engage the male side of the metal roof deck panel.

FABRAL INC ([View Classification](#)) — "Stand'N Seam Clip"

3. **Fasteners** — (Screws) — The fastener used to attach the panel clips to the purlins to be No. 12 x 1 in. self-drilling, self-tapping, plated steel screw. Two screws per clip inserted into guide holes.

4. **Purlins** — No. 16 MSG min gauge steel (50,000 psi min yield strength) spaced a max of 60 in. OC.

Refer to General Information, Roof Deck Constructions, (Roofing Materials and Systems Directory) for items not evaluated.

*** Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.**

Last Updated on 1996-12-14

Feedback

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2023 UL LLC."