

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015272-R2
DATE: 05/10/2021
CERTIFICATION PROGRAM: Structural
COMPANY: Shwinco
CODE: 1972-1
REVISION DATE: 12/03/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Shwinco Architectural Products, LLC 171 Jet Services Way Dothan, AL 36303	Series "6500" Vinyl Casement Window Configuration: X Glazing: IG-1/8" Annealed Glass/1/8" Annealed Glass/0.060" Eastman Chemical PVB Interlayer/1/8" Annealed Glass Frame: W-940mm(37") H-1930mm(76") Vent: W-849mm(33.44") H-1865mm(73.44") DLO: W-718mm(28.25") H-1708mm(67.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 ASTM E2395-18	Class LC-PG70 940 x 1930 (37 x 76)-C Design Pressure: ±3352 Pa (70 psf) Water Penetration Resistance Test Pressure: 510 Pa (10.68 psf) Window Performance Level: L5

Product Tested By: Intertek, PLC
Report No: NCTL 210-4199-3/NCTL 210-4199-3A/J3468.01-550-18/NCTL-210-4214-2/W-1994
Expiration Date: **February 28, 2027**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shin".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023