NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI014435-R4**
DATE:	**06/04/2019**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Shwinco**
CODE:	**1972-1**
REVISION DATE:	**08/18/2026**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Shwinco Architectural Products, LLC **171 Jet Services Way** **Dothan, AL 36303**	**Series "9500"** **Vinyl Casement Window** Configuration: X Glazing: IG-1/8" Annealed Glass/1/8" Annealed Glass/0.090" Eastman Chemical Saflex Interlayer/1/8" Annealed Glass Frame: W-940mm(37") H-1930mm(76") Vent: W-849mm(33.44") H-1865mm(73.44") DLO: W-718mm(28.25") H-1708mm(67.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 **AAMA/WDMA/CSA 101/I.S.2/A440-11** **ASTM E1886-05/13a** **ASTM E1996-05/09/17** **TAS 201/202/203-94**	**Class LC-PG70 940 x 1930 (37 x 76)-C** **Design Pressure: ±3352 Pa (70 psf)** **Water Penetration Resistance Test Pressure: 510 Pa (10.68 psf)** **Wind Zone 4-Missile Level D** **Large Missile Impact Rated**

Product Tested By: Intertek, PLC
Report No: NCTL 210-4199-3/NCTL 210-4199-3A/J3468.01-550-18
Expiration Date: **December 31, 2029**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com