NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI014436-R3**
DATE:	**06/04/2019**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Shwinco**
CODE:	**1972-1**
REVISION DATE:	**04/18/2024**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Shwinco Architectural Products, LLC **171 Jet Services Way** **Dothan, AL 36303**	**Series "9500"** **Vinyl Awning Window** Configuration: X Glazing: IG-1/8" Annealed Glass/1/8" Annealed Glass/0.090" Eastman Chemical Saflex Interlayer/1/8" Annealed Glass Frame: W-1346mm(53") H-914mm(36") Vent: W-1281mm(50.44") H-849mm(33.44") DLO: W-1124mm(44.25") H-692mm(27.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 **AAMA/WDMA/CSA 101/I.S.2/A440-11** **ASTM E1886-05/13a** **ASTM E1996-05/09/17** **TAS 201/202/203-94**	**Class LC-PG70 1346 x 914 (53 x 36)-AP** **Design Pressure: ±3352 Pa (70 psf)** **Water Penetration Resistance Test Pressure: 510 Pa (10.65 psf)** **Wind Zone 4-Missile Level D** **Large Missile Impact Rated**

Product Tested By: Intertek, PLC
Report No: J0530.07-550-18/J0530.04-550-18/NCTL-210-4199-4/ NCTL-210-4199-4A
Expiration Date: **December 31, 2026**

Administrator's Signature:_____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com