

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014436-R4
DATE: 06/04/2019
CERTIFICATION PROGRAM: Structural
COMPANY: Shwinco
CODE: 1972-1
REVISION DATE: 08/18/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Shwinco Architectural Products, LLC 171 Jet Services Way Dothan, AL 36303	Series "9500" Vinyl Awning Window Configuration: X Glazing: IG-1/8" Annealed Glass/1/8" Annealed Glass/0.090" Eastman Chemical Saflex Interlayer/1/8" Annealed Glass Frame: W-1346mm(53") H-914mm(36") Vent: W-1281mm(50.44") H-849mm(33.44") DLO: W-1124mm(44.25") H-692mm(27.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 ASTM E1886-05/13a ASTM E1996-05/09/17 TAS 201/202/203-94	Class LC-PG70 1346 x 914 (53 x 36)-AP Design Pressure: ±3352 Pa (70 psf) Water Penetration Resistance Test Pressure: 510 Pa (10.65 psf) Wind Zone 4-Missile Level D Large Missile Impact Rated

Product Tested By: Intertek, PLC
Report No: J0530.07-550-18/J0530.04-550-18/NCTL-210-4199-4/
NCTL-210-4199-4A
Expiration Date: December 31, 2029

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shin".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023