# NOTICE OF PRODUCT CERTIFICATION

| | |
|---|---|
| **CERTIFICATION NO:** | **NI011053.03-R6** |
| **DATE:** | **04/09/2012** |
| **CERTIFICATION PROGRAM:** | **Structural** |
| **COMPANY:** | **Loewen** |
| **CODE:** | **1862-1** |
| **REVISION DATE:** | **10/16/2023** |

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---|---|
| **Loewen**<br>**77 Highway 52 West**<br>**Steinbach, Manitoba R5G 1B2** | **Series "25" Wood**<br>**Double Hung Window**<br><br>Configuration: X/X<br>Glazing: Insulating Glass (Annealed)<br><br>Frame: W-1062mm(41.81") H-1632mm(64.25")<br>Sash: W-979mm(38.56") H-824mm(32.44") |

| SPECIFICATION | PRODUCT RATING |
|---|---|
| **AAMA/WDMA/CSA 101/I.S.2/A440-08**<br>**AAMA/WDMA/CSA 101/I.S.2/A440-05** | **LC-PG55 1062 x 1632 (42 x 64)-H**<br>**H-LC55 1062 x 1632 (42 x 64)**<br>**Design Pressure: 2640 Pa (55 psf)**<br>**Negative Design Pressure: 3360 Pa (70 psf)**<br>**Water Penetration Resistance Test Pressure: 400 Pa (8.25 psf)**<br>**Canadian Air Infiltration/Exfiltration Level: A3** |

Product Tested By: Architectural Testing, Inc.
Report No: B0383.01-201-44/A6171.01-201-44/W-1567/W-1818
Expiration Date: **August 31, 2027**

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.**
**4794 George Washington Memorial Highway**
**Hayes, VA 23072**
**Tel: (804) 684-5124**
**Email: nami@namiinc.com**