| | Document Title: | Doc No: FRM B1-43 | |
|---|---|---|---|
| KEYSTONE CERTIFICATIONS, INC. | **Impact Performance Certification Authorization Report** | Rev No: 4 | Page: 1 Of: 1 |
| Required By: PRO B1-03 | | | |

CAR & Product ID Number: 1071 - 206
Issue Date: 12/21/2017
Revision Date: 12/14/2020
Expiration Date: 12/21/2024
Company Code: 1071

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

| **Licensee Information:** | **Product Information:** |
|---|---|
| Gaulhofer Industrie-Holding GmbH<br>Guggenbach 7<br>Uebelbach, 8124<br>Austria | Model: Fusionline 94 Outswing Side Hinge Door XX<br>Operator Type: SHD<br>Config: SR, GS-5/16" HS Lami IG<br>Max Width: 83<br>Max Height: 107<br>Corresponding Structural CARs: 1071-114 |

| **Referenced Standard:** | **Product Rating:** |
|---|---|
| ASTM E1886-13a, ASTM E1996-14a | Missile Lever D, Wind Zone 3, DP +/-50, 83x107 |

| **Qualifying Test Information:** | |
|---|---|
| Test Report No: | ATI-C2638.01-401-44 |
| Test Report Expiration: | 12/21/2024 |

**Authorized Signature:**

KEYSTONE CERTIFICATIONS, INC. Validations Manager

2020.12.14 11:34:48 -05'00'

**Keystone Certifications, Inc.**
145 Limekiln Rd., Suite 100B
New Cumberland, Pennsylvania 17070
Phone: 717-932-8500
Fax: 717-932-8501