

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010967-R5
DATE: 02/06/2012
CERTIFICATION PROGRAM: Structural
COMPANY: Window Crafts.
CODE: 690-1
REVISION DATE: 11/26/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Window Craftsmen 6031 Clark Center Avenue Sarasota, FL 34238	Series "PW-300" Vinyl Fixed Impact Rated Window (Screw, Fin & Strap Installation) Configuration: O Glazing: Laminate-5/32" Annealed Glass/Laminate-5/32" Annealed Glass/0.090" DuPont Sentry Glass Plus Interlayer/5/32" Annealed Glass or IG-Laminate-5/32" Annealed Glass/0.090" DuPont Sentry Glass Plus Interlayer/5/32" Annealed Glass/5/32" Annealed Glass Frame: W-1346mm(53") H-1956mm(77") DLO: W-1226mm(48.25") H-1835mm(72.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 ASTM E1886-02/05/13a/E1996-02/05/14a TAS 201/202/203-94	Class R-PG70 1346 x 1956 (53 x 77)-FW FW-R70 1346 x 1956 (53 x 77) Design Pressure: ±3360 Pa (70 psf) Wind Zone 4-Missile Level D Large Missile Impact Rated

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-14728-1/NCTL-110-14728-2/NCTL-110-14738-3/
NCTL-110-14728-4/NCTL-110-14728-5/NCTL-110-14738-6/W-1965
Expiration Date: **June 30, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023