

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012871-R3
DATE: 09/30/2015
CERTIFICATION PROGRAM: Structural
COMPANY: Window Crafts
CODE: 690-1
REVISION DATE: 11/26/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Window Craftsmen 6031 Clark Center Avenue Sarasota, FL 34238	Series "SS-201" Vinyl Horizontal Sliding Window Configuration: OX Glazing: Insulating Glass (Annealed) Frame: W-1880mm(74") H-1600mm(63") Panel: W-923mm(36.31") H-1527mm(60.12")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	Class CW-PG45 1880 x 1600 (74 x 63)-HS HS-C45 1880 x 1600 (74 x 63) Design Pressure: ±2160 Pa (45 psf) Water Penetration Resistance Test Pressure: 440 Pa (9 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: AIR-INS, Inc.
Report No: AI-02982-I/W-1965
Expiration Date: July 31, 2030

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "S.M.D.", written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023