NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI011286.02-R2**
DATE:	**04/12/2021**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Eastern**
CODE:	**1783-1**
REVISION DATE:	**01/07/2025**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems **16341 Domestic Avenue** **Ft. Myers, FL 33912**	**Series "FWI 1000 Horizontal Roller"** **Aluminum Equal Lite** **Horizontal Sliding Window** Configuration: XOX Glazing: IG - 1/8" Annealed Glass/1/8" Annealed Glass/0.090"Saflex PVB Interlayer/1/8" Annealed Glass or Monolithic - 1/8" Annealed Glass/0.090" Saflex PVB Interlayer/1/8" Annealed Glass Frame: W-2819mm(111") H-1930mm(76") Panel: W-935mm(36.81") H-1819mm(71.63") DLO: W-856mm(33.69") H-1807mm(71.13")

SPECIFICATION	PRODUCT RATING
ASTM E1886-13a/E1996-14a **TAS 201/202/203-94**	**Design Pressure: ±2873 Pa (±60 psf)** **Water Penetration Resistance Test Pressure: 431 Pa (9.0 psf)** **Wind Zone 4-Missile Level D** **Large Missile Impact Rated**

Product Tested By: Blackwater Technical Services, Inc.
Report No: BT-EAS-20-002/W-2044
Expiration Date: **March 31, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com