

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI011287-R1  
**DATE:** 09/28/2012  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Eastern  
**CODE:** 1783-1  
**REVISION DATE:** 02/09/2016

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Eastern Architectural Systems</b> <b>16341 Domestic Avenue</b> <b>Ft. Myers, FL 33912</b>	<b>Series "HR 1000S" Aluminum</b> <b>Flange Frame Equal Lite</b> <b>Horizontal Sliding Window</b>  Configuration: OX Glazing: IG-Laminate-1/8" Annealed Glass/0.090"Saflex by Solutia Interlayer/1/8" Annealed Glass/1/8" Annealed Glass or Monolithic: Laminate-1/8" Annealed Glass/0.090" Saflex by Solutia Interlayer/1/8" Annealed Glass  Frame: W-1880mm(74") H-1829mm(72") Panel: W-911mm(35.88") H-1743mm(68.63")

SPECIFICATION	PRODUCT RATING
<b>ASTM E1886-05/E1996-06</b> <b>TAS 201/202/203-94</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b>	<b>Design Pressure: +60/-60 psf</b> <b>Wind Zone 4-Missile Level D</b> <b>Large Missile Impact Rated</b> <b>HS-C60 1880 x 1829 (74 x 72)</b>

Product Tested By: Element Materials Technology  
Report No: ESP009274P-3/ESP009274P-4/ESP009274P-8/ESP009274P-9  
Expiration Date: April 30, 2021

Administrator's Signature: \_\_\_\_\_ 

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122