

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011271-R5
DATE: 09/14/2012
CERTIFICATION PROGRAM: Structural
COMPANY: Regency
CODE: 750-1
REVISION DATE: 04/04/2022

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Regency Plus, Inc. 2000 Locust Gap Highway Mount Carmel, PA 17851	Series "Tech 5111" Vinyl Horizontal Sliding Window Configuration: XO Glazing: IG-Interior-1/8" Tempered Glass/ Exterior-Laminate-1/8" Annealed Glass/0.090" DuPont PVB Interlayer/1/8" Annealed Glass Frame: W-1880mm(74") H-1270mm(50") Panel: W-911mm(35.87") H-1191mm(46.88)

SPECIFICATION	PRODUCT RATING
ASTM E1886-05/E1996-02/04/06/09 TAS 201/202/203-94 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	Design Pressure: +55/-70 psf Wind Zone 4-Missile Level D Large Missile Impact Rated Class R-PG55 1880 x 1270 (74 x 50)-HS HS-R55 1880 x 1270 (74 x 50) Negative Design Pressure: 3360 Pa(70 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-14748-1/NCTL-110-14748-2/NCTL-110-14748-3/W-1901/
W-1979

Expiration Date: **July 31, 2028**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com