



Structural Performance Certification Authorization Report

Slocomb Windows and Doors, Inc.

767 Sans Souci Parkway
Hanover Twp, PA 18706, USA

Certification ID:	286-1963
Company Code:	286
Certification Date:	1/20/2023
Revision:	1
Revision Date:	3/2/2026
Expiration Date:	1/20/2027

Product Rating Information:

Model:	500 Series Double Hung		
Operator Type:	H		
Configuration:	AV/Clip/EM/IM		
Referenced Standard:	AAMA/WDMA/CSA 101/IS2/A440-11		
Product Rating:	See Appendix 1 Load Table		
Rated Dimensions:	Max Width:	See Table	Max Height: See Table

Qualifying Test Information:

Test Report No:	ATI-E5079.03-501-47
Test Report Expiration:	1/20/2027

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standards. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of certification labels for the Keystone Fenestration Certification Program. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.



Authorized By:

Shaun Shaull
Shaun Shaull 2026.03.02
10:33:39 -05'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500



Structural Performance Certification Authorization Report

Revision History

Rev #	Date	Description
0	1/20/2023	Initial Issuance.
1	3/2/2026	Addded Load Table.



Appendix 1

CAR No: 286-1963_R1
Expiration Date: 1/20/2027

Slocomb Windows and Doors, Inc

767 Sans Souci Parkway
Hanover Twp, PA 18706

Load Tables for the:

500 Series Double Hung

Chart #1
Rating by comparison (psf)

Frame Height (in)	Frame width (in)													
	30.00		36.00		42.00		48.00		52.00		54.00		60.00	
	Pos	Neg	Pos	Neg	Pos	Neg	Pos	Neg	Pos	Neg	Pos	Neg	Pos	Neg
24.00	50.0	82.5	50.0	82.5	50.0	82.5	50.0	82.5	50.0	82.5	50.0	82.5	50.0	82.5
30.00	50.0	82.5	50.0	82.5	50.0	82.5	50.0	82.5	50.0	82.5	50.0	82.5	50.0	81.9
36.00	50.0	82.5	50.0	82.5	50.0	82.5	50.0	82.5	50.0	82.5	50.0	82.5	50.0	69.0
42.00	50.0	82.5	50.0	82.5	50.0	82.5	50.0	82.5	50.0	81.8	50.0	78.0	50.0	60.0
48.00	50.0	82.5	50.0	82.5	50.0	82.5	50.0	82.5	50.0	74.3	50.0	70.7	50.0	53.3
54.00	50.0	82.5	50.0	82.5	50.0	82.5	50.0	76.5	50.0	68.6	50.0	65.2	48.2	48.2
60.00	50.0	82.5	50.0	82.5	50.0	82.5	50.0	72.0	50.0	64.2	50.0	60.9	44.3	44.3
66.00	50.0	82.5	50.0	82.5	50.0	77.1	50.0	67.5	50.0	60.8	50.0	57.6	41.1	41.1
72.00	50.0	82.5	50.0	82.5	50.0	70.7	50.0	61.9	50.0	57.1	50.0	55.0	38.6	38.6
75.00	50.0	82.5	50.0	79.2	50.0	67.9	50.0	59.4	50.0	54.8	50.0	52.8	37.6	37.6