

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016196
DATE: 05/21/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Croft
CODE: 1887-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Croft, LLC 1800 North Clark Avenue Magnolia, MS 39652	Series "20W" Vinyl Single Hung Window Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-914mm(36") H-1829mm(72") Sash: W-848mm(33.38") H-889mm(35") DLO: W-775mm(30.50") H-816mm(32.13")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/1.S.2/A440-17	Class R-PG35 914 x 1829 (36 x 72)-H Design Pressure: ±1680 Pa (±35 psf) Water Penetration Resistance Test: 260 Pa (5.43 psf)

Product Tested By: PRI Construction Materials Technologies, LLC
Report No: 2189T0057
Expiration Date: April 30, 2028

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023