

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI011395-R6  
**DATE:** 01/10/2013  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Ply Gem  
**CODE:** 1408-1  
**REVISION DATE:** 03/03/2022

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

| COMPANY NAME AND ADDRESS                                                                    | PRODUCT DESCRIPTION                                                                                                                                                                                                                                  |
|---------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Ply Gem Window Group</b><br><b>433 North Main Street</b><br><b>Rocky Mount, VA 24151</b> | <b>"Ply Gem 1500"</b><br><b>Vinyl Tilt Single Hung Window</b><br><b>Integral Mull Twin</b><br><br>Configuration: XX<br>Glazing: Insulating Glass (Annealed)<br><br>Frame: W-2140mm(84.25") H-1959mm(77.12")<br>Sash: W-999mm(39.31") H-956mm(37.63") |

| SPECIFICATION                                                                                                                                      | PRODUCT RATING                                                                                                                                                                                                                                                                                                         |
|----------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b><br><b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b><br><b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b><br><b>CSA A440S1-09</b> | <b>Class LC-PG40 2140 x 1959 (84 x 77)-H</b><br><b>H-LC40 2140 x 1959 (84 x 77)</b><br><b>Design Pressure: 1920 Pa (40 psf)</b><br><b>Negative Design Pressure: 1920 Pa (40 psf)</b><br><b>Water Penetration Resistance Test Pressure: 360 Pa (7.5 psf)</b><br><b>Canadian Air Infiltration/Exfiltration Level: A2</b> |

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-15642-1/W-1717/W-1758/W-1831/W-1867  
Expiration Date: November 30, 2026

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)