

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI011395.05-R6  
**DATE:** 01/10/2013  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Ply Gem  
**CODE:** 1408-1  
**REVISION DATE:** 03/03/2022

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

| COMPANY NAME AND ADDRESS                                                                    | PRODUCT DESCRIPTION                                                                                                                                                                                                                                     |
|---------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Ply Gem Window Group</b><br><b>433 North Main Street</b><br><b>Rocky Mount, VA 24151</b> | <b>"Ply Gem 1500"</b><br><b>Vinyl Tilt Single Hung Window</b><br><b>Integral Mull Triple</b><br><br>Configuration: XOX<br>Glazing: Insulating Glass (Annealed)<br><br>Frame: W-3075mm(121.06") H-1957mm(77.06")<br>Sash: W-953mm(37.5") H-954mm(37.56") |

| SPECIFICATION                                                                                                                                      | PRODUCT RATING                                                                                                                                                                                                                                                                                                             |
|----------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b><br><b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b><br><b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b><br><b>CSA A440S1-09</b> | <b>Class LC-PG45 3075 x 1957 (121 x 77)-H</b><br><b>H-LC45 3075 x 1957 (121 x 77)</b><br><b>Design Pressure: 2160 Pa (45 psf)</b><br><b>Negative Design Pressure: 2160 Pa (45 psf)</b><br><b>Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)</b><br><b>Canadian Air Infiltration/Exfiltration Level = A2</b> |

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-15644-1/NCTL-110-15645-1/W-1717/W-1758/W-1867  
Expiration Date: November 30, 2026

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be 'MD' or similar, written over a horizontal line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)