NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI012583-R7**
DATE:	**03/17/2015**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Ply Gem**
CODE:	**1408-1**
REVISION DATE:	**07/25/2024**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group **433 North Main Street** **Rocky Mount, VA 24151**	**Series "Ply Gem 1500"** **Vinyl Tilt Flanking Single Hungs with Center Fixed Lite** Configuration: XOX Glazing: Insulating Glass (Annealed) Frame: W-2729mm(107.44") H-1961mm(77.19") Sash: W-835mm(32.9") H-954mm(37.6") FW DLO: W-784mm(30.9") H-1842mm(72.5")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 **AAMA/WDMA/CSA 101/I.S.2/A440-11** **AAMA/WDMA/CSA 101/I.S.2/A440-08** **AAMA/WDMA/CSA 101/I.S.2/A440-05** **CSA A440S1-09**	**Class LC-PG25 2729 x 1961 (107 x 77)-H** **H-LC25 2729 x 1961 (107 x 77)** **Design Pressure: ±1680 Pa (35 psf)** **Water Penetration Resistance Test Pressure: 180 Pa(3.76 psf)** **Canadian Air Infiltration/Exfiltration Level: A2**

Product Tested By: National Certified Testing Laboratories
Report No: 110-17758-1/NCTL-110-15590-1/NCTL-110-15597-1/W-1758/W-1831/W-1867/W-2010/W-2112/W-2125
Expiration Date: **October 31, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com