NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI013800.10-R6**
DATE:	**07/30/2017**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Ply Gem**
CODE:	**1408-1**
REVISION DATE:	**07/25/2024**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group **433 North Main Street** **Rocky Mount, VA 24151**	**Series "1500"** **Twin Tilt Vinyl Single Hung** **w/Integral Mullion** Configuration: O/X//O/X Glazing: Insulating Glass (Annealed) Frame: W-1816mm(71.5") H-1868mm(73.56") Sash: W-837mm(32.94") H-906mm(35.68")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 **AAMA/WDMA/CSA 101/I.S.2/A440-17** **AAMA/WDMA/CSA 101/I.S.2/A440-11** **AAMA/WDMA/CSA 101/I.S.2/A440-08** **AAMA/WDMA/CSA 101/I.S.2/A440-05** **CSA A440S1-09**	**Class R-PG50 1816 x 1868 (72 x 74)-H** **H-R50 1816 x 1868 (72 x 74)** **Design Pressure: 2400 Pa (50 psf)** **Negative Design Pressure: 2400 Pa (50 psf)** **Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)** **Canadian Air Infiltration/Exfiltration Level: A2**

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-20107-1/NCTL-110-16822-1/W-1831/W-1867/W-2112/W-2047 /W-2125
Expiration Date: **December 31, 2028**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com