

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013800.12-R1
DATE: 05/26/2020
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 05/16/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	Series "1500" Twin Vinyl Single Hung w/Integral Mullion Configuration: O/XO/X Glazing: Insulating Glass (Annealed) Frame: W-1816mm(71.5") H-2121mm(83.5") Sash: W-837mm(32.94") H-1038mm(40.08") DLO: W-784mm(30.88") H-975mm(38.38")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-17	Class LC-PG35 1829 x 2134* (72 x 84*)-H Design Pressure: ± 1680 Pa (± 35 psf) Positive Design Pressure: 1920 Pa (40 psf) Negative Design Pressure: 1920 Pa (40 psf) Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-23159-1/NCTL-110-15601-1
Expiration Date: December 31, 2027

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com