

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014621.01-R5
DATE: 01/08/2020
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
DATE: 08/06/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	Series "1500 SH Integral Mull" Triple Vinyl Tilt Single Hung Window Configuration: O/X//O/X//O/X Glazing: Insulating Glass (Annealed) Frame: W-2730mm(107.5") H-1664mm(65.5") Sash: W-838mm(33") H-803mm(31.63") DLO: W-783mm(30.81") H-752mm(29.63")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-17	Class LC-PG35 2730 x 1664* (108 x 66*)-H Design Pressure: ±1680 Pa (35 psf) Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: National Certified Testing Laboratories
Report No: NCTL 110-22709-1/NCTL 110-22707-1/W-2125
Expiration Date: September 30, 2030

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi D".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023