NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI011395.19-R6**
DATE:	**04/19/2013**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Ply Gem**
CODE:	**1408-1**
REVISION DATE:	**03/27/2025**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group **433 North Main Street** **Rocky Mount, VA 24151**	**"Ply Gem 1500"** **Vinyl Fixed Window** **Integral Mull Twin** Configuration: OO Glazing: Insulating Glass (Annealed) Frame: W-2045mm(80.5") H-1827mm(71.94") Sash: W-851mm(37.44") H-889mm(35")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 **AAMA/WDMA/CSA 101/I.S.2/A440-11** **AAMA/WDMA/CSA 101/I.S.2/A440-08** **AAMA/WDMA/CSA 101/I.S.2/A440-05** **CSA A440S1-09**	**Class LC-PG50 2045 x 1827 (81 x 72)-H** **H-LC50 2045 x 1827 (81 x 72)** **Design Pressure: 2400 Pa (50 psf)** **Negative Design Pressure: 2400 Pa (50 psf)** **Water Penetration Resistance Test Pressure: 360 Pa (7.5 psf)** **Canadian Air Infiltration/Exfiltration Level = A2**

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-15641-1/NCTL-110-15642-1/W-1558/W-1996/W-2112/W-2125
Expiration Date: **November 30, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com