

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011395.20-R6
DATE: 04/19/2013
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1411-1
REVISION DATE: 03/27/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	"Ply Gem 1500" Vinyl Fixed Window Integral Mull Twin Configuration: OO Glazing: Insulating Glass (Annealed) Frame: W-2140mm(84.25") H-1959mm(77.12") Sash: W-999mm(39.31") H-956mm(37.63")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 CSA A440S1-09	Class LC-PG40 2140 x 1959 (84 x 77)-H H-LC40 2140 x 1959 (84 x 77) Design Pressure: 1920 Pa (40 psf) Negative Design Pressure: 1920 Pa (40 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.5 psf) Canadian Air Infiltration/Exfiltration Level = A2

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-15642-1/W-1558/W-1996/W-2112/W-2125
Expiration Date: November 30, 2027

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com

NOPC 03/30/2023