

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011358.06-R9
DATE: 12/17/2012
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 04/08/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	"Ply Gem 1500" Vinyl Horizontal Sliding Window Configuration: XOX Glazing: Insulating Glass (Annealed) Frame: W-2440mm(96.06") H-1829mm(72") Panel: W-776mm(30.56") H-1754mm(69.06")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 CSA A440S1-09	Class R-PG15 2440 x 1829 (96 x 72)-HS HS-R15 2440 x 1829 (96 x 72) Design Pressure: 720 Pa (15 psf) Negative Design Pressure: 720 Pa (15 psf) Water Penetration Resistance Test Pressure: 330 Pa (6.89 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-15631-1/W-1717/W-1758/W-1831/W-1867/W-2112/W-2125/W-2010
Expiration Date: October 31, 2030

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC 03/30/2023