

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011358.13-R7
DATE: 06/14/2013
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 07/07/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	"Ply Gem 1500" Impact Rated Vinyl Horizontal Sliding Window Configuration: O/X Glazing: IG-1/8" Annealed Glass/Laminate- 1/8" Annealed Glass/0.090" Solutia Interlayer/ 1/8" Annealed Glass Frame: W-1599mm(62.94") H-1221mm(48.06") Panel: W-764mm(30.06") H-1146mm(45.13")

SPECIFICATION	PRODUCT RATING
AAMA 506-06/08/11/16/23 ASTM E1886-05/13a/19 ASTM E1996-02/04/06/09/12/12a/20 AAMA/WDMA/CSA 101/I.S.2/A440-22 AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	Design Pressure: +50/-60 psf Wind Zone 3-Missile Level D Class LC-PG50 1599 x 1221 (63 x 48)-HS HS-LC50 1599 x 1221 (63 x 48) Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2880 Pa (60 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-16008-1/NCTL-110-15628-1/W-1758/W-1867/W-1958/
W-2047/W-2112/W-2196
Expiration Date: January 31, 2031

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com

NOPC 03/30/2023