

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011350.20-R9  
DATE: 06/21/2013  
CERTIFICATION PROGRAM: Structural  
COMPANY: Ply Gem  
CODE: 1408-1  
REVISION DATE: 07/07/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS                                                                    | PRODUCT DESCRIPTION                                                                                                                                                                                              |
|---------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Ply Gem Window Group</b><br><b>433 North Main Street</b><br><b>Rocky Mount, VA 24151</b> | <b>"Ply Gem 1500"</b><br><b>Vinyl Tilt Single Hung Window</b><br><br>Configuration: O/X<br>Glazing: Insulating Glass (Annealed)<br>Frame: W-913mm(35.94") H-2134mm(84")<br>Sash: W-849mm(33.44") H-949mm(37.38") |

| SPECIFICATION                                                                                                                                                                                                                          | PRODUCT RATING                                                                                                                                                                                                                                                                                                       |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-22</b><br><b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b><br><b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b><br><b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b><br><b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b><br><b>CSA A440S1-09</b> | <b>Class LC-PG50 913 x 2134 (36 x 84)-H</b><br><b>H-LC50 913 x 2134 (36 x 84)</b><br><b>Design Pressure: 2400 Pa (50 psf)</b><br><b>Negative Design Pressure: 2400 Pa (50 psf)</b><br><b>Water Penetration Resistance Test Pressure: 360 Pa (7.5 psf)</b><br><b>Canadian Air Infiltration/Exfiltration Level: A2</b> |

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-16027-1/NCTL-110-15598-1/W-1717/W-1758/W-1831/W-1867/W-2047/W-2112/W-2125/W-2196  
Expiration Date: **March 30, 2031**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)

NOPC 03/30/2023