

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011350.12-R6
DATE: 12/19/2012
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 05/14/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	"Ply Gem 1500" Vinyl Tilt Single Hung Window Configuration: O/X Glazing: IG-1/8" Annealed Glass (Interior)/ Laminate-1/8" Annealed Glass/0.090" Solutia Interlayer/1/8" Annealed Glass (Exterior) Frame: W-967mm(38.06") H-1957mm(77.06") Sash: W-900mm(35.44") H-954mm(37.56")

SPECIFICATION	PRODUCT RATING
AAMA 506-06/08/11/16 AAMA/WDMA/CSA 101/LS.2/A440-17 AAMA/WDMA/CSA 101/LS.2/A440-11 AAMA/WDMA/CSA 101/LS.2/A440-08 AAMA/WDMA/CSA 101/LS.2/A440-05 CSA A440S1-09 ASTM E1886-02/05/13a/E1996-02/05/12a	Overall Design Pressure: +50/-60 psf Wind Zone 3-Missile Level D Class LC-PG50 967 x 1957 (38 x 77)-H H-LC50 967 x 1957 (38 x 77) Negative Design Pressure: 2873 Pa (60 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.5 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: **National Certified Testing Laboratories**
Report No: **NCTL-110-15653-2/NCTL-110-15653-1/W-1758/W-1867/W-1958/
W-2010**
Expiration Date: **November 30, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023