NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI011337.02-R6**
DATE:	**11/25/2012**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Ply Gem**
CODE:	**1408-1**
REVISION DATE:	**02/18/2026**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group **433 North Main Street** **Rocky Mount, VA 24151**	**"Ply Gem 1500"** **Vinyl Fixed Window** Configuration: O Glazing: Insulating Glass (Tempered) Frame: W-1829mm(72") H-2438mm(96") DLO: W-1715mm(67.5") H-2324mm(91.5")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 **AAMA/WDMA/CSA 101/I.S.2/A440-11** **AAMA/WDMA/CSA 101/I.S.2/A440-08** **AAMA/WDMA/CSA 101/I.S.2/A440-05**	**Class CW-PG40 1829 x 2438 (72 x 96)-FW** **FW-CW40 1829 x 2438 (72 x 96)** **Design Pressure: 1920 Pa (40 psf)** **Negative Design Pressure: 2160 Pa (45 psf)** **Water Penetration Resistance Test Pressure: 580 (12.11 psf)** **Canadian Air Infiltration/Exfiltration Level = Fixed Level**

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-15592-1/W-1831/W-2112/W-2010
Expiration Date: **November 30, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com