

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011337.04-R6
DATE: 12/06/2012
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 02/18/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	"Ply Gem 1500" Impact Rated Vinyl Fixed Window Configuration: O Glazing: IG-1/8" Annealed Glass (Interior)/ Laminate-1/8" Annealed Glass/0.090" Solutia Interlayer/1/8" Annealed Glass (Exterior) Frame: W-1524mm(60") H-1827mm(71.94") DLO: W-1408mm(55.44") H-1713mm(67.44")

SPECIFICATION	PRODUCT RATING
AAMA 506-06/08/11/16 AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 ASTM E1886-05/13a ASTM E1996-05/12a	Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2880 Pa (60 psf) Wind Zone 3-Missile Level D Structural Performance*: Class LC-PG50 1524 x 1827 (60 x 72)-FW FW-LC50 1524 x 1827 (60 x 72) Water Penetration Resistance Test Pressure: 580 (12.1 psf) Canadian Air Infiltration/Exfiltration Level: Fixed Level

*Original Structural Performance of Product Exceeded Size and Performance of Impact Testing

Product Tested By: **National Certified Testing Laboratories**
Report No: **NCTL-110-15615-1/W-1958/W-2010**
Expiration Date: **November 30, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023