NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI014492-R3**
DATE:	**08/28/2019**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Ply Gem**
CODE:	**1408-1**
REVISION DATE:	**07/25/2024**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group **433 North Main Street** **Rocky Mount, VA 24151**	**Series "1500"** **Vinyl Fixed Window** Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-1829mm(72") H-2438mm(96") DLO: W-1711mm(67.38") H-2321mm(91.38")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 **AAMA/WDMA/CSA 101/I.S.2/A440-11** **AAMA/WDMA/CSA 101/I.S.2/A440-08** **CSA A440S1-17**	**Class LC-PG45 1829 x 2438 (72 x 96)-FW** **Design Pressure: ±2160 Pa (45 psf)** **Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf)** **Canadian Air Infiltration/Exfiltration Level: Fixed**

Product Tested By: National Certified Testing Laboratories
Report No: NCTL 110-22293-1/W-2112/W-2125
Expiration Date: **May 31, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com