

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014492.03-R4
DATE: 12/11/2019
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 11/20/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	Series "1500" Vinyl Fixed Window Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-1219mm(48") H-2438mm(96") DLO: W-1103mm(43.44") H-2321mm(91.38")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-17	Class LC-PG45 1219 x 2438* (48 x 96*)-FW Design Pressure: ±2160 Pa (45 psf) Water Penetration Resistance Test Pressure: 510 Pa (10.65 psf) Canadian Air Infiltration/Exfiltration Level: Fixed

Product Tested By: National Certified Testing Laboratories
Report No: NCTL 110-22291-1/NCTL 110-22673-1/W-2112/W-2125/W-2010
Expiration Date: April 30, 2030

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC 03/30/2023