

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011260.01-R4
DATE: 01/02/2013
CERTIFICATION PROGRAM: Structural/Impact
COMPANY: Bildau & Bussman
CODE: 1651-1
REVISION DATE: 09/08/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Bildau & Bussmann North America, Inc. 200 Continental Drive, Suite 401 Newark, DE 19713	"Lift-Slide" Aluminum Clad Wood Sliding Glass Door Configuration: XOX Glazing: Monolithic-Laminate-1/4" Tempered Glass/0.090" DuPont SGP/1/4" Tempered Glass or IG-1/4" Tempered Glass/Laminate-1/4" Tempered Glass /0.090" DuPont SGP/1/4" Tempered Glass Frame: W-5588mm(220") H-3048mm(120") Sash: W-1636mm(64.38") H-2915mm(114.75") Panel: W-2413mm(95.00") H-2915mm(114.75")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: +70/-70 psf Large Missile Impact Rated Qualifies Configurations: XO/OX/XOX

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-3800-4/W-1541
Expiration Date: **June 30, 2029**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi" or similar, written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023