	Document Title:	Doc No: FRM B1-43	
KEYSTONE CERTIFICATIONS, INC.	**Impact Performance Certification Authorization Report**	Rev No: 4	Page: 1 Of: 1
Required By: PRO B1-03			

CAR & Product ID Number: 588 - 202
Issue Date: 11/15/2012
Revision Date: 9/24/2020
Expiration Date: 3/14/2022
Company Code: 588

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information:	**Product Information:**
Window Mart Mfg. LLC. 5760 Albert Pike, PO Box 570 Royal, AR 71968 USA	Model: 6101 Impact NC Single Hung Operator Type: H Config: EM/All/Clip/SR/Sill, GS-5/16" Ann Lami IG Max Width: 48 Max Height: 72 Corresponding Structural CARs: 588-190.0

Referenced Standard:	**Product Rating:**
ASTM E1886-12/E1996-12a	Missile Level D, Wind Zone 4, DP +/-50, 48x72

Qualifying Test Information:	
Test Report No:	ESP 009376P-2R/011308P-2R
Test Report Expiration:	3/14/2022

Authorized Signature:

2020.09.24
12:35:55 -04'00'

Keystone Certifications, Inc.
145 Limekiln Rd., Suite 100B
New Cumberland, Pennsylvania 17070
Phone: 717-932-8500
Fax: 717-932-8501