NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011423-R1

DATE: 02/05/2013

CERTIFICATION PROGRAM: Structural

COMPANY: <u>Eastern</u>

CODE: <u>1783-1</u>

REVISION DATE: 05/12/2016

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS		PRODUCT DESC	CRIPTION
Eastern Architectural Systems	1	Series "400 Impac	t Tilt Turn"
16341 Domestic Avenue	Vi	nyl Replacement I	Frame Impact
Fort Myers, FL 33912	Dual Action Window		
	Configuration: X Glazing: IG-Interior-1/4" Annealed Glass/ Exterior Laminate-3/16" Annealed Glass/ 0.075" Interlayer by Vanceva/3/16" Annealed Glass		
	Frame:	W-1219mm(48")	H-1803mm(71")
	Sash:	W-1149mm(45.25")	H-1734mm(68.25")

SPECIFICATION	PRODUCT RATING	
AAMA 506-08	Design Pressure: +100/-105 psf	
ASTM E1886-05/E1996-06	Wind Zone 4-Missile Level D	
TAS 201/202/203-94	Large Missile Impact Rated	
AAMA/WDMA/CSA 101/I.S.2/A440-05	DAW-C100 1219 x 1803 (48 x 71)	
	Negative Design Pressure: 5027 Pa (105 psf)	

Product Tested By: Element Materials Technology Report No: ESP009981P-8/ESP009981P-9

Expiration Date: <u>July 31, 2021</u>

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124 Fax: (804) 684-5122