

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011424.01-R1
DATE: 02/05/2013
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern
CODE: 1783-1
REVISION DATE: 05/12/2016

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems 16341 Domestic Avenue Fort Myers, FL 33912	Series "400 Non-Impact Tilt Turn" Vinyl Replacement Frame Dual Action Window Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-1219mm(48") H-1803mm(71") Sash: W-1149mm(45.25") H-1734mm(68.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-05 TAS 202-94	DAW-C100 1219 x 1803 (48 x 71) Design Pressure: 4788 Pa (100 psf) Negative Design Pressure: 5027 Pa (105 psf)

Product Tested By: Element Materials Technology
Report No: ESP009981P-10/ESP009981P-11/W-1552
Expiration Date: July 31, 2021

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be 'Shi' or similar, written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122