

	Document Title: Impact Performance Certification Authorization Report	Doc No: FRM B1-43	
		Rev No: 4	Page: 1 Of: 1
Required By: PRO B1-03			

CAR & Product ID Number: 464 - 244

Issue Date: 6/30/2014

Revision Date: 9/30/2020

Expiration Date: 10/30/2024

Company Code: 464

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information:	Product Information:
Viwinco, Inc. 851 Hemlock Rd, Morgantown Business Par Morgantown, PA 19543-0499 USA	Model: Oceanview Imp Fixd Csmnt Over Csmnt Comb Ass'y Operator Type: C Config: H/J/S/Mull/AlI/Snub, GS-5/16" Ann Lami IG Max Width: 36 Max Height: 108 Corresponding Structural CARs: 464-702.0

Referenced Standard:	Product Rating:
ASTM E1886-13a/E1996-17	Missile Level D, Wind Zone 3, DP +/-50, 36x108

Qualifying Test Information:	
Test Report No:	ATI-D0912.02-109-47/ATI-K0178.01-109-47
Test Report Expiration:	10/30/2024

Authorized Signature:



2020.09.30

11:18:35 -04'00'

Keystone Certifications, Inc.

145 Limekiln Rd., Suite 100B
New Cumberland, Pennsylvania 17070
Phone: 717-932-8500
Fax: 717-932-8501