



**AUTHORIZATION FOR PRODUCT CERTIFICATION**

**Simonton Windows**  
**1 Cochrane Dr.**  
**Pennsboro, WV 26415**

**Attn: Tina Seese**

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED			
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08 R-PG65*-940x1930 (37x76)-H Negative Design Pressure = -70 psf</b>	<b>PA 201, 202, 203</b>				
COMPANY AND CODE	Missile Level: <b>Large</b> Rating: <b>+65/-70, 37x76</b>  Rating above conforms to the requirements of: <b>TAS 201, TAS 202</b> and <b>TAS 203</b>	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
<b>Simonton Windows Code: SIM</b>		<b>12487</b>	<b>07-09 STORMBREAKER PLUS DH (PVC)(X/X)(OG) (INS TEMP/PVB LAM GL) (MODIF)(REINF)(TILT) (ASTM)</b>	<b>FRAME (mm) 940 x 1930 (3'1" x 6'4")</b>	<b>SASH (mm) 857 x 946 (2'10" x 3'1")</b>

This Certification will expire **May 22, 2022 (extended from May 22, 2017 per AAMA 103-15)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Structural Test & Report By:

**Architectural Testing, Inc.**

Report No: **D0296.01-501-47**

Date of Report: **August 20, 2013**


Missile Impact Test & Report By:

**Architectural Testing, Inc.**

Report No: **C8533.01-501-18; D3023.01-501-18**

Date of Report: **January 14, 2014; January 17, 2014**

Evaluated for Certification: **January 18, 2017**

  
 Associated Laboratories, Inc.

Authorized for Certification: **January 18, 2017**

  
 American Architectural Manufacturers Association