

**AAMA
CERTIFICATION PROGRAM**



AUTHORIZATION FOR PRODUCT CERTIFICATION

**Simonton Windows
1 Cochrane Ave.
Pensboro, WV 26415**

Attn: Tina Seese

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The listing below will be added to the next update to the AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-08 R-PG50-2870x1600 (113x63)-HS	PAS 201, 202, 203				
COMPANY AND PLANT LOCATION	Missile Level: Large Rating: +50/-50, 113x63 Rating above conforms to requirements of: TAS 201, TAS 202 and TAS 203	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
Simonton Windows Code: SIM		16294	07-09/07-20 STORMBREAKER PLUS HS (PVC) (XOX) (OG) (INS TEMP/PVB LAM GL) (MODIF) (ASTM)	<u>FRAME(mm)</u> 2870 x 1600 (9'5" x 5'3")	<u>VENT(mm)</u> 841 x 1391 (2'9" x 4'7")

1. This Certification will expire **October 12, 2021** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

2. Structural Test & Report By:

PRI Construction Materials Technologies; UL, LLC

Report No: **SIMO-028-03-02; SV30832-20170201**

Date of Report: **October 27, 2016; February 2, 2017**

Missile Impact Test & Report by:

UL, LLC

Report No: **SV30832-20170201**

Date of Report: **February 2, 2017**

*****ALL CERTIFIED PRODUCTS MUST BE PRODUCED WITH TEMPERED AND LAMINATED GLASS.*****

Evaluated for Certification: **February 17, 2017**

Associated Laboratories, Inc.

Authorized for Certification: **February 17, 2017**

American Architectural Manufacturers Association

SBS/JTS