



**AUTHORIZATION FOR PRODUCT CERTIFICATION**

**Simonton Windows  
1 Cochrane Ave.  
Pensboro, WV 26415**

**Attn: Tina Jenkins**

The product described below is hereby approved for listing in the next issue of the AAMA Certified Products Directory. The approval is based on successful completion of tests, and the reporting to the Administrator of the results of tests, accompanied by related drawings, by an AAMA Accredited Laboratory.

1. The listing below will be added to the next published AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED			
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08 R-PG50-1854x1372 (73x54)-HS</b>	<b>TAS 201, 202, 203</b>				
<b>COMPANY AND PLANT LOCATION</b>	Missile Level: <b>Large</b> Rating: <b>+50/-50, 73x54</b> Rating above conforms to requirements of: <b>TAS 201, TAS 202 and TAS 203</b>	<b>CPD NO.</b>	<b>SERIES MODEL &amp; PRODUCT DESCRIPTION</b>	<b>MAXIMUM SIZE TESTED</b>	
<b>Simonton Windows Code: SIM</b>		<b>8587</b>	<b>07-09 SLIDER (STORMBREAKER PLUS) (PVC) (OX) (OG) (INS TEMP/LAM GL) (REINF) (MODIF) (ASTM)</b>	<b><u>FRAME(mm)</u> 1854 x 1372 (6'1" x 4'6")</b>	<b><u>SASH(mm)</u> 908 x 1264 (3'0" x 4'2")</b>

2. This Certification will expire **April 20, 2020 (extended from April 20, 2015 per AAMA 103-14a)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

3. Structural Test & Report By:

**Architectural Testing, Inc.**

Report No: **A9263.01-501-47**

Date of Report: **May 17, 2011**

Missile Impact Test & Report by:

**Architectural Testing, Inc.**

Report No: **B8415.01-501-18 Revision 1**

Date of Report: **April 19, 2012**

**\*\*\*ALL CERTIFIED PRODUCTS MUST BE PRODUCED WITH TEMPERED AND LAMINATED GLASS.\*\*\***

Validated for Certification- March 14, 2017

Associated Laboratories, Inc.

Authorized for Certification- March 14, 2017

American Architectural Manufacturers Association

Date: **April 26, 2012**  
Revised: **March 14, 2017**  
Cc: AAMA  
SBS