

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011565.04-R4
DATE: 05/23/2013
CERTIFICATION PROGRAM: Structural
COMPANY: ProVia Door
CODE: 1212-1
REVISION DATE: 08/14/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
ProVia LLC 2150 State Route 39 Sugarcreek, OH 44681	Steel Single In-Swing Glazed Side Hinged Door w/Transom Configuration: O over X Glazing: IG-Exterior-1/8" Tempered Glass/ Interior-Laminate-1/8" Annealed Glass/0.090" Solutia Interlayer/1/8" Annealed Glass or IG-Exterior-Laminate-1/8" Annealed Glass/0.090" Solutia Interlayer/1/8" Annealed Glass/Center-1/8" Tempered Glass/Interior-1/8" Tempered Glass/ IG-Exterior-1/8" Tempered Glass/Center-1/8" Tempered Glass/Laminate-1/8" Annealed Glass/0.090" Solutia Interlayer/1/8" Annealed Glass or IG-Exterior-1/8" Tempered Glass/Center- Decorative Inlay/Interior-Laminate-1/8" Annealed Glass/0.090" Solutia Interlayer/1/8" Annealed Glass or IG-Exterior-1/8" Tempered Glass/Center-Wrought Iron Decorative Inlay/Interior-Laminate-1/8" Annealed Glass/0.090" Solutia Interlayer/1/8" Annealed Glass Frame: W-954mm(37.56") H-3284mm(129.28")

SPECIFICATION	PRODUCT RATING
ASTM E283-04(12)/E330-02(10)/ ASTM E1886-04/05/E1996-02/04/06/09/12a	Design Pressure: 2633 Pa (55 psf) Wind Zone 3-Missile Level D Qualifies Configurations: O over X

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-15660-1/NCTL-110-15660-2/W-1561/W-1569/W-2002/
W-2084/W-2104/W-2105/W-2170
Expiration Date: **December 31, 2028**

Administrator's Signature: _____

**NATIONAL ACCREDITATION &
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com

NOPC 03/30/2023