

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011610.05-R8
DATE: 07/17/2013
CERTIFICATION PROGRAM: Structural
COMPANY: ProVia Door
CODE: 1212-1
REVISION DATE: 07/29/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
ProVia LLC 2150 State Route 39 Sugarcreek, OH 44681	Fiberglass In-Swing Opaque Side Hinged Double Door w/Sidelites & Transom Configuration: O/OXXO Sidelite & Transom Glazing: IG (Double)-Ext-1/8" Tempered Glass/Int-Laminate-1/8" Annealed Glass/0.090" Solutia PVB Interlayer/1/8" Annealed Glass or Transom IG (Triple): Exterior-Center Lites-1/8" Tempered Glass/Int-Laminate-1/8" Annealed Glass/0.090" Solutia PVB Interlayer/1/8" Annealed Glass Frame: W-3321mm(130.78") H-3310mm(130.34") Panel: W-908mm(35.75") H-2411mm(94.94")

SPECIFICATION	PRODUCT RATING
ASTM E330-02 ASTM E1886-04/05/E1996-02/04/06/09/12a	Design Pressure: 2633 Pa (55 psf) Wind Zone 3-Missile Level D

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-15660-1/NCTL-110-15660-2/NCTL-110-15650-2/NCTL-110-1560-4/NCTL-110-15651-2/NCTL-110-15652-2/NCTL-110-15652-3/W-1616/W-2002/W-2084/W-2105/W-2170/W-2199

Expiration Date: **December 31, 2028**

Administrator's Signature: _____

**NATIONAL ACCREDITATION &
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com