

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011536-R4  
DATE: 04/10/2013  
CERTIFICATION PROGRAM: Structural  
COMPANY: Eastern  
CODE: 1783-1  
REVISION DATE: 03/17/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS                                                                           | PRODUCT DESCRIPTION                                                                                                                                                                                                                                                                                                      |
|----------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Eastern Architectural Systems</b><br><b>16341 Domestic Avenue</b><br><b>Ft. Myers, FL 33912</b> | <b>Series "HD 2451/2461"</b><br><b>Vinyl Single Hung</b><br><b>Impact Rated Window</b><br><br>Configuration: O/X<br>Glazing: IG-1/8" Annealed Glass/<br>Laminate-1/8" Annealed Glass/0.090" Solutia Interlayer/<br>1/8" Annealed Glass<br><br>Frame: W-1118mm(44") H-2134mm(84")<br>DLO: W-995mm(39.19") H-1130mm(44.5") |

| SPECIFICATION                                                            | PRODUCT RATING                                                                                                                                                                     |
|--------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b><br><b>ASTM E1886-05/E1996-05b</b> | <b>Class R-PG65 1118 x 2134 (44 x 84)-H</b><br><b>Design Pressure: 3120 Pa (65 psf)</b><br><b>Negative Design Pressure: 3120 Pa (65 psf)</b><br><b>Wind Zone 4-Missile Level D</b> |

Product Tested By: Construction Consulting Laboratory, International  
Report No: CCLI-11-160/CCLI-12-010/W-2184  
Expiration Date: September 30, 2027

A handwritten signature in black ink, appearing to be "MD".

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023