

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012195-R3
DATE: 11/20/2014
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern
CODE: 1783-1
REVISION DATE: 03/17/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems 16341 Domestic Avenue Ft. Myers, FL 33912	Series "176.043" Vinyl Single Hung Window w/Fin or Flange Frame Configuration: O/X Glazing: IG-Ext-3/16" Annealed Glass/Laminate-1/8" Annealed Glass/0.090" SGP Interlayer by DuPont/1/8" Annealed Glass Frame: W-1372mm(54") H-1956mm(77") Panel: W-1334mm(50.37") H-940mm(37.75")

SPECIFICATION	PRODUCT RATING
AAMA 506-08 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 ASTM E1886-05/E1996-09 TAS 201/202/203-94	Design Pressure: ± 3351 Pa (70 psf) Class LC-PG70 1372 x 1956 (54 x 77)-H H-LC70 1372 x 1956 (54 x 77) Positive Design Pressure: 3351 Pa (70 psf) Negative Design Pressure: 4069 Pa (85 psf) Wind Zone 4-Missile Level D Large Missile Impact Rated Water Penetration Resistance Test Pressure: 502 Pa(10.50 psf)

Product Tested By: Certified Testing Laboratories, Inc.
Report No: CTLA-3005WA/CTLA-3005WD/W-2184
Expiration Date: **June 30, 2027**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi D".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023