

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011461-R3
DATE: 02/14/2013
CERTIFICATION PROGRAM: Structural
COMPANY: ProVia Door
CODE: 1212-1
REVISION DATE: 01/10/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
ProVia Door, Inc. 2150 State Route 39 Sugarcreek, OH 44681	Series "Transom" Composite Fixed Transom (Double & Triple Glazed) Configuration: O Double Glazing: IG-Exterior-1/8" Tempered Glass/ Interior Laminate-1/8" Annealed Glass/0.090" Solutia Interlayer/1/8" Annealed Glass or Triple Glazing: IG-Exterior-1/8" Tempered Glass/ Center-1/8" Tempered Glass/Interior Laminate-1/8" Annealed Glass/0.090" Solutia Interlayer/ 1/8" Annealed Glass Frame: W-2481mm(97.69") H-805mm(31.69") DLO: W-2405mm(94.69") H-729mm(28.69")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/1.S.2/A440-05/08 ASTM E283-04(12)/E330-02(10)/ E331-00(09)/E547-00(09) ASTM E1886-04/05/E1996-02/04/06/09/12a	Class CW-PG55 2480 x 805 (98 x 32)-TR TR-C55 2480 x 805 (98 x 32) Design Pressure: 2633 Pa (55 psf) Wind Zone 3-Missile Level D Water Penetration Resistance Test Pressure: 400 Pa (8.25 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-15652-1/NCTL-110-15652-2/NCTL-110-15652-3
Expiration Date: **December 31, 2028**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com

NOPC 03/30/2024