NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI011590-R6**
DATE:	**06/24/2013**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Shwinco**
CODE:	**1972-1**
REVISION DATE:	**03/26/2026**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Shwinco Architectural Products, LLC **171 Jet Services Way** **Dothan, AL 36303**	**Series "9700" Impact Rated** **Vinyl Sliding Glass Door** (1.75" Sill Riser) Configuration: XO Glazing: IG-Ext-3/16" Tempered Glass/ Int-Laminate-3/16" Annealed Glass/0.090" Interlayer by Solutia/3/16" Annealed Glass Frame: W-2438mm(96") H-2438mm(96") Sash: W-1257mm(49.5") H-2369mm(93.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 **AAMA/WDMA/CSA 101/I.S.2/A440-08** **ASTM E1886-02/04/05/13a** **ASTM E1996-04/06/09/14a** **TAS 201/202/203-94**	**Class LC-PG60 2438 x 2438 (96 x 96)-SD** **Design Pressure: ±2873 Pa (±60 psf)** **Water Penetration Resistance Test Pressure: 504 Pa (10.5 psf)** **Wind Zone 4-Missile Level D** **Large Missile Impact Rated**

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-3886-1/NCTL-210-3886-1A/W-1930
Expiration Date: **May 31, 2028**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com