

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011669-R6
DATE: 09/16/2013
CERTIFICATION PROGRAM: Structural
COMPANY: Mulia
CODE: 1991-1
REVISION DATE: 03/30/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Mulia Incorporated 100 Business Center Drive # 12 Ormond Beach, FL 32174	"LW Glass Block" Vinyl Fixed Window Configuration: O Glazing: Nominal 3/8" Thick Annealed Pattern Glass Frame: W-1438mm(56.62") H-1438mm(56.62") DLO: W-1368mm(53.87") H-1368mm(53.87")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/LS.2/A440-11	Class LC-PG110 1438 x 1438 (57 x 57)-FW Design Pressure: 5280 Pa (110 psf) Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf)

Product Tested By: Architectural Testing, Inc.
Report No: C7461.01-401-44
Expiration Date: May 31, 2026

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

e-mail: nami@namiinc.com