

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012511.06
DATE: 11/19/2024
CERTIFICATION PROGRAM: Structural
COMPANY: YKK AP America
CODE: 860-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
YKK AP America, Inc. 101 Marietta Street NW, Suite 2100 Atlanta, GA 30303	StyleGuard® "5400" Vinyl Sliding Door Configuration: OX Glazing: IG-3/16" Tempered Glass/1/8" Annealed Glass/0.090" Saflex PVB Interlayer/1/8" Annealed Glass Frame: W-2426mm(95.50") H-2426mm(95.50") Panel: W-1219mm(48") H-2337mm(92") DLO: W-1041mm(41") H-2172mm(85.50")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: ±2400 Pa (±50 psf) Large Missile Impact Rated

Product Tested By: Architectural Testing Incorporated
Report No: E0597.07-550-18/W-2088/W-2139
Expiration Date: December 31, 2027

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi".

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com

NOPC-03/30/2023