

Hallmark® Certificate of Conformance and License (CCL)




AMS, INC.
Administrative Management
Systems, Inc.


FrontLine Bldg. Products Inc.
610 Jensen Dr.
PO Box 505
PO Box 505
Medford, WI 54451-1665

Mfr ID: 0830
For more Information visit www.amscert.com
Website: www.frontlinebldg.com
TEL:

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
0830-H-002.11	500 Series Clad Outswing Door - Fixed Door	101/I.S.2/A440-11	Class LC-PG50; Size Tested 953mm x 2438mm Type-FD; DP +50/-50 psf; Water Test Press 360Pa (7.52psf)	953mm	2438mm	QCT13-2991.01-R2	10/23/2015	6/20/2023
0830-H-002.20	500 Series Clad Outswing Door - XXO, OXX, XX, OX, XO,X	101/I.S.2/A440-11	Class LC-PG50; Size Tested 6.88 m2 x 2438mm Type-MA; DP +50/-50 psf; Water Test Press 360Pa (7.52psf)	6.88 m2	2438mm	QCT13-2991.01-R2	11/4/2015	6/20/2023

WDMA HEREBY CERTIFIES that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected by WDMA, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  *John McFee, VP of Certification Programs, WDMA Hallmark*

By:  *Rhonda Schotz, Authorized Representative, AMS*

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 100 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com