NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012196-R2

DATE: 11/20/2014

CERTIFICATION PROGRAM: Structural

COMPANY: <u>Eastern</u>

CODE: 1783-1

REVISION DATE: 12/30/2014

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status.

Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems	Series "176 SS"
10030 Bavaria Road	Vinyl Horizontal Sliding Window
Ft. Myers, FL 33913	w/Fin Frame
	Configuration: XOX Glazing: IG-Ext-3/16" Annealed Glass/Laminate-1/8" Annealed Glass/0.090" SGP Interlayer by DuPont/1/8"Annealed Glass
	Frame: W-2189mm(111.00") H-1600mm(63.00")
	Panel: W-937mm(36.87") H-1538mm(60.56")

SPECIFICATION	PRODUCT RATING
AAMA 506-08 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 ASTM E1886-05/E1996-09 TAS 201/202/203-94	Design Pressure: ±2872 Pa (60 psf) Class LC-PG60 2819 x 1600 (111 x 63)-HS HS-LC60 2819 x 1600 (111 x 63) Positive Design Pressure: 2872 Pa (60 psf) Negative Design Pressure: 3352 Pa (70 psf) Wind Zone 4-Missile Level D Large Missile Impact Rated Water Penetration Resistance Test Pressure: 502 Pa(10.50 psf)

Product Tested By: Certified Testing Laboratories, Inc.
Report No: CTLA-3005W-1A/CTLA-3005W-1D

Expiration Date: June 30, 2018

Administrator's Signature: ____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124

Fax: (804) 684-5122