

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011859.10-R1
DATE: 02/21/2014
CERTIFICATION PROGRAM: Structural
COMPANY: NewSouth
CODE: 2013-1
REVISION DATE: 09/15/2015

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Doers Window Manufacturing, LLC 4901 Oak Fair Boulevard Tampa, FL 33610	"9500" New Construction Frame Vinyl Horizontal Sliding Window Configuration: XO Glazing: Insulating Glass (Annealed) Frame: W-1524mm(60.00") H-1524mm(60.00") Sash: W-756mm(29.75") H-1462mm(57.56") DLO: W-673mm(26.50") H-1416mm(55.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class LC-PG55 1524 x 1524 (60 x 60)-HS Design Pressure: 2640 Pa (55 psf) Negative Design Pressure: 2640 Pa (55 psf) Water Penetration Resistance Test Pressure: 400 Pa(8.35 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: Architectural Testing Incorporated
Report No: C7536.07-501-44
Expiration Date: May 31, 2017

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be 'S. D.', written over a horizontal line.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122