

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012055.01-R2
DATE: 07/09/2014
CERTIFICATION PROGRAM: Structural
COMPANY: NewSouth
CODE: 2013-1
REVISION DATE: 09/15/2015

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Doers Window Manufacturing, LLC 4901 Oak Fair Boulevard Tampa, FL 33610	Series "9500-3" Vinyl Horizontal Roller Window Replacement or New Construction Configuration: XOX Glazing: IG-1/8" Annealed Glass/Laminate-1/8" Annealed Glass/0.105" Solutia Saflex PVB Interlayer/1/8" Annealed Glass and IG-1/8" Annealed Glass/Laminate-1/8" Annealed Glass/Solutia Saflex PVB Interlayer/1/8" Annealed Glass Frame: W-2819mm(111.00") H-1600mm(63.00") Sash: W-721mm(28.37") H-1543mm(60.75") DLO: W-1295mm(51.00") H-1543mm(57.25")

SPECIFICATION	PRODUCT RATING
ASTM E1886-05/E1996-05 TAS 201/202/203-94	Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2633 Pa (55 psf) Wind Zone 4 - Missile Level D Large Missile Impact Rated

Product Tested By: Architectural Testing Incorporated
Report No: D0238.03-401-44/D0238.04-401-44
Expiration Date: **June 30, 2018**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122